

Whisdom New Change Notifications

Manchester Airports requirements

Reference	Issue Date	Title	Details	Drawing Reference if Applicable	Action
PI AA/October 08/21	Tuesday 21st October 2008	Change to the Reception desk mosaic tile Specification	Change to the reception desk mosaic tile specification from J&R Johnson TERH 24 to Johnson Tiles AA 3030 PORT 18005 Tile size 23 x 23 x 6 mm Up-dated drawings 4.05a & 10.13b refer		Cost tba if applicable
PTI AA/Oct 08/No.20a	Monday 6th October 2008	Further change to the specification of decoration below corridor dado rail	Decorations below corridor dado rail is to change from Natural Aubergine painted Glasstex GTP59 to Dixon Turner wall paper ref DT-WTI 35		Cost tba if applicable
PTI AA/Oct 08/No.19	Friday 3rd October 2008	Change to linen room heater specification	Change to the specification of the Linen room heaters. New heaters are to be duplex oil filled wall mounted heater.	Up-dated drawings 5.11a & 5.12a and attachment reference OPX 100	Cost tba if applicable
PI AA/July 08/16	Friday 25th July 2008	Product code change for UA basin mixer tap to include plug and chain	Confirmation of the change in product code for the UA basin Tap complete with stay and chain Ref Q9064L. Description HG Focus E Single lever basin mixer with Chain Please note that this code does not include the plug and waste Plug & waste Code C50024-1/4" basin waste & chrome plug. There is an initial lead in period for this product of 3-4 weeks		Cost tba if applicable
PI AA/June 08/09	Monday 23rd June 2008	Provision of bottle opener within bedrooms	Provision of a bottle opener fixed to grooming tower in both Standard & UA bedrooms	Product Code E780028 drawings 5.01a, 5.05a, 5.10a & 5.17a refer to be fitted by multibuild	Cost for fixing
PI AA/June 08/08	Monday 23rd June 2008	Change to the fixing height of a standard bedroom bedhead pad	Change to the fixing height of a standard bedroom bedhead pad fixing height from 710mm to 690mm above carpet level	Drawings 5.01a 5.10a refer	No change in cost
PI AA/April 08/04	Friday 18th April 2008	UA WHB provision of Plug & Chain	All UA WHB's are to be supplied with a plug and change in lieu of a captive waste - To comply with DDA Requirements for access and use		Cost tba if applicable
PI AA/April 08/03	Friday 18th April 2008	New Product code for Staff WC Doc M Pack	Product Code change for the Staff WC DOC M Pack which now has Blue Grab rails to conform to DDA requirements for a visual Contrast between rails colour and wall colour Wolsley Product Code for a DOC M pack with Blue rails is B79224 The product description is Saracen standard DOC M pack blue rails		Cost tba if applicable
PI AA/April 08/02	Friday 18th April 2008	New Product code for drop down grab rails	Product Code change for the drop down grab rails within UA Shower and bathrooms - Grab rails now supplied with drop down leg Wolsley Product Code for the Polished stainless steel hinged arm grab rail with integral support leg, 850mm long is E69124.		Cost tba if applicable
PTI AA/Jan 08/No.48	Monday 21st January 2008	Change in Specification to Bedroom Bulkhead ceiling tile	Change in the specification of the bedroom bulkhead ceiling tile from Rockfon Alaska tegular to Rockfon Alaska A24 600 x 600	Drawing 3.08a refers	Cost tba if applicable
PTI AA/Jan 08/No.49	Monday 21st January 2008	UA Shower room- Omit of some wall tiling	Omission of wall tiling from Elevation C & within alcove to WHB	Drawing 3.08a refers	No change in cost

pti AA/Jan 08/No50	Monday 21st January 2008	Standard bedroom bedhead SSSO outlet location amended	Standard bedroom - Location of SSSO within left handside bedhead tower amended	Drawing 5.01g & 5.16b refers	No change in cost
pti AA/Jan 08/No44	Friday 18th January 2008	Change to fixing height of UA Bedroom coat rail	Change to the fixing height of the UA bedroom coat rail	Drawings 5.05h & 5.17b refer	No change in cost
pti AA/Jan 08/No46	Friday 18th January 2008	Changes to reception desk lighting	Changes to the number and setting out of the lighting over the Reception desk and amendments to the Light schedule.	Drawing 4.01f refers	Cost tba if applicable

3962/CRH/MF
1st December 2008

HOTEL, PRINCESS STREET, EDINBURGH
ELECTRICAL SERVICES INSTALLATION
CLARIFICATIONS TO PREMIER INN SPECIFICATION (Sept 2007 Edition, Revised 1.10.07)

- Section 4.3 - Extent of external lighting and supplies to external illuminated signage to be in accordance with Planning Authority restrictions.-AGREED
- Section 4.6 - Cable basket 'only' will be provided by Developer;
All I.T. cabling, outlets and hardware equipment to be supplied/installed by Tenant.-
AGREED
- Section 4.7 - T.V coaxial cabling 'only' will be provided by Developer;
All central T.V equipment, aerials, satellite dish and televisions to be
supplied/installed by Tenant.- AGREED
- Section 4.9 - Electrical supplies and containment 'only' for CCTV, Intruder Alarm and Access
Control Installations to be provided by Developer;AGREED
All security systems, cabling and equipment to be supplied/installed by Tenant.
AGREED
- Electrical supply 'only' for P.A/Music Installation to be provided by Developer;
All cabling and equipment to be supplied/installed by Tenant. AGREED
 - Power Factor Correction Installation shall not be provided by Developer.
 - Requirement for smoke ventilation, dry riser and associated fire fighting generator
(presently excluded) will be subject to Fire Engineers Agreement with Local
Authorities.AGREED AND PROVIDED BY THE DEVELOPER